

---

**Licensing Inspection Report ( General Inspection )**

Facility: SHANNEX RLC LIMITED (Caritas Residence)

Address: 215 SETON RD.  
HALIFAX NS, B3M 0C9

Date(s) of Inspection: January 25, 2023

---

**Requirements resulting from licensing inspection:**

1. HSCR 27(11)  
No person shall be maintained in a home for special care or any part thereof that is not approved by a Fire Marshal with respect to fire safety.
2. LTCPR 12.2.1.8  
The licensee shall ensure root causes analyses of building and maintenance issues related to compromised functionality, including but not limited to, surface integrity and aesthetic integrity are identified, analyzed and corrected.
3. LTCPR 9.2.1.a  
The licensee shall ensure there is a documented All Hazards Plan which is reviewed a minimum of every three years and revised as necessary to ensure the plan is current. The All Hazards Plan shall address: emergency evacuation, emergency relocation, emergency expansion, emergency isolation, bomb threat / suspicious package, external air exclusion, chemical spill, violent person and facility access control.