
Licensing Inspection Report (Annual Inspection)

Facility: SHANNEX RLC LIMITED (CARITAS RESIDENCE)

Address: 215 SETON RD.
HALIFAX NS, B3M 0C9

Date(s) of Inspection: June 1, 2022

Requirements resulting from licensing inspection:

1. LTCPR 9.2.4.a
The licensee shall ensure there is a documented Fire Safety Plan, in accordance with the National Fire Code, that is reviewed a minimum of annually and revised as necessary to ensure the plan is current.
2. LTCPR 9.2.2 c
The licensee shall ensure the Business Continuity Plan is reviewed a minimum of annually and revised as necessary to ensure it is current.