
Licensing Inspection Report (Semi-Annual Inspection)

Facility: HARBOURVIEW LODGE CONTINUING CARE CENTRE

Address: 22639 HIGHWAY 7 HWY.
SHEET HARBOUR NS, B0J 3B0

Date(s) of Inspection: September 23, 2024

Requirements resulting from licensing inspection:

1. HSCR 27(8), LTCPR 9.2.4.d, LTCPR 9.2.4.e
The licensee shall ensure fire protection equipment is maintained in good working order. Fire alarms and fire doors are tested monthly; fire extinguishers are inspected monthly and tested annually in accordance with the Office of the Fire Marshal. Records of testing and inspections of fire protection equipment and systems are maintained.