
Licensing Inspection Report (Annual Inspection)

Facility: LONDON HALL ENHANCED CARE

Address: 694 BROAD ST.
BEDFORD NS,

Date(s) of Inspection: September 9, 2025

Requirements resulting from licensing inspection:

1. HSCR 27(7), LTCPR 9.2.4.b
The licensee shall ensure fire drills are conducted a minimum of monthly in accordance with direction from the Office of the Fire Marshal.
2. HSCR 27(8), LTCPR 9.2.4.d, LTCPR 9.2.4.e
The licensee shall ensure fire protection equipment is maintained in good working order. Fire alarms and fire doors are tested monthly; fire extinguishers are inspected monthly and tested annually in accordance with the Office of the Fire Marshal. Records of testing and inspections of fire protection equipment and systems are maintained.
3. HSCR 27(11), LTCPR 9.2.4.g
No person shall be maintained in a home for special care or any part thereof that is not approved by a Fire Marshal with respect to fire safety.