
Licensing Inspection Report (Annual Inspection)

Facility: MOUNTAIN LEA LODGE

Address: 170 CHURCH ST.
BRIDGETOWN NORTH NS, B0S 1C0

Date(s) of Inspection: June 29, 2021

Requirements resulting from licensing inspection:

1. LTCPR 7.1.12
The licensee shall ensure required inspections of the home and equipment are completed and documentation is maintained to demonstrate compliance with requirements. These include, but are not limited to, manufacturer requirements, safety requirements, sprinkler systems, water testing, fire alarms and fuel systems.
2. HSCR 27(6), LTCPR 9.2.8
The licensee shall ensure upon initial employment in a home and a minimum of annually thereafter, every staff member is instructed in and understands the contents of the All Hazards Plan, the Fire Safety Plan, the Business Continuity Plan and the Staff Call Back System Plan as applicable to their individual roles. Every staff member shall be thoroughly instructed in the method of evacuation during an emergency situation and shall be familiar with the location of all fire alarm boxes, extinguishers and exits in the home, prior to commencing active duty in the home.
3. LTCPR 11.1.6
The licensee shall ensure the home provides a documented, timely orientation for all staff members, volunteers and contracted personnel. The orientation provides the necessary information to support residents in a safe manner and improve their quality of life.