
Licensing Inspection Report (Annual Inspection)

Facility: MY CAPE BRETON HOME FOR SENIORS
INCORPORATED (Sydney)

Address: 137 RIVERDALE DR.
WESTMOUNT NS, B1R 0A9

Date(s) of Inspection: May 2, 2022

Requirements resulting from licensing inspection:

1. HSCR 27(8), LTCPR 9.2.4.d, LTCPR 9.2.4.e
The licensee shall ensure fire protection equipment is maintained in good working order. Fire alarms and fire doors are tested monthly; fire extinguishers are inspected monthly and tested annually in accordance with the Office of the Fire Marshal. Records of testing and inspections of fire protection equipment and systems are maintained.