
Licensing Inspection Report (Semi-Annual Inspection)

Facility: NORTHSIDE GENERAL HOSPITAL

Address: 520 PURVES ST.
NORTH SYDNEY NS, B2A 1E3

Date(s) of Inspection: April 22, 2021.

Requirements resulting from licensing inspection:

1. LTCPR 9.2.4.b
The licensee shall ensure fire drills are conducted a minimum of monthly in accordance with direction from the Office of the Fire Marshal.