
Licensing Inspection Report (Annual Inspection)

Facility: NORTHSIDE GENERAL HOSPITAL

Address: 520 PURVES ST.
NORTH SYDNEY NS, B2A 1E3

Date(s) of Inspection: August 21, 2025

Requirements resulting from licensing inspection:

1. LTCPR 7.1.12
The licensee shall ensure required inspections of the home and equipment are completed and documentation is maintained to demonstrate compliance with requirements. These include, but are not limited to, manufacturer requirements, safety requirements, sprinkler systems, water testing, fire alarms and fuel systems.
2. LTCPR 12.2.2.2.c
The licensee shall ensure aesthetic, functional and surface integrity of the following are maintained: interior building components such as, but not limited to, partitions, ceilings, doors, casework, coatings and sealants.
3. LTCPR 7.2.3
The licensee shall ensure resident council meetings are held monthly. Residents and/or authorized designates are notified of meetings in advance and are encouraged to participate.
4. LTCPR 9.2.4.a
The licensee shall ensure there is a documented Fire Safety Plan, in accordance with the National Fire Code, that is reviewed a minimum of annually and revised as necessary to ensure the plan is current.
5. HSCR 19(1)(d), LTCPR 11.1.6
The licensee shall ensure the home provides a documented, timely orientation for all staff members, volunteers and contracted personnel. The orientation provides the necessary information to support residents in a safe manner and improve their quality of life.

Outstanding requirements from previous inspection(s):

1. Date of inspection: August 26, 2024; November 12, 2024 and August 21, 2025
LTCPR 6.3.2

The licensee shall ensure an interdisciplinary care conference, that includes the resident and/or authorized designate and the family members approved by the resident, is conducted within six weeks of admission to the home and annually thereafter, or more frequently as the resident's individual needs require.