
Licensing Inspection Report (Annual Inspection)

Facility: ST. ANNE COMMUNITY AND NURSING CARE CENTRE

Address: 2313 HIGHWAY 206 HWY.
ARICHAT NS, B0E 1A0

Date(s) of Inspection: October 20, 2025

Requirements resulting from licensing inspection:

1. HSCR 27(6), LTCPR 9.2.8
The licensee shall ensure upon initial employment in a home and a minimum of annually thereafter, every staff member is instructed in and understands the contents of the All Hazards Plan, the Fire Safety Plan, the Business Continuity Plan and the Staff Call Back System Plan as applicable to their individual roles. Every staff member shall be thoroughly instructed in the method of evacuation during an emergency situation and shall be familiar with the location of all fire alarm boxes, extinguishers and exits in the home, prior to commencing active duty in the home.
2. LTCPR 9.2.4.a
The licensee shall ensure there is a documented Fire Safety Plan, in accordance with the National Fire Code, that is reviewed a minimum of annually and revised as necessary to ensure the plan is current.
3. LTCPR 6.3.6
The licensee shall ensure staff members document timely, clear, objective and complete information on the resident record.
4. LTCPR 7.3.3
Requirements for Nursing Homes - The licensee shall ensure family council meetings are held a minimum of twice annually. Family members are notified of meetings in advance and are encouraged to participate.